

## - Declaration of Conformity -

CE Mark

MIKEL JAUREGUIZAR DE ZÁRATE declares:

As General Manager of the company Normagrup Technology S.A. that the surface mounted emergency lights mentioned below comply with all related standards.

COMMERCIAL BRAND: **DUNNA**

References:

D-100L, D-100L-1, D-100L-2, D-150L, D-150L-1, D-150L-2, D-200L, D-200L-1, D-200L-2, D2-200L, D2-200L-1, D2-200L-2, D2-400L, D2-400L-1, D2-400L-2, D-300L, D-300L-1, D-300L-2, D-30L, D-30L-1, D-30L-2, D3-200L, D3-200L-1, D3-200L-2, D3-60L, D3-60L-1, D3-60L-2, D-400L, D-400L-1, D-400L-2, D-500L, D-500L-1, D-500L-2, D-600L, D-600L-1, D-600L-2, D-60L, D-60L-1, D-60L-2, DID2-200L, DID2-200L-1, DID2-200L-2

Meet the requirements of the **Low Voltage Directive of the European 2014/35/UE** (standards EN60598-2-22:2014, EN60598-1:2015, EN62471:2008 and EN62493:2015). Equally they meet the requirements of the **Electromagnetic Compatibility Directive (EMC)**, 2014/30/UE (standards EN55015:2013, EN61547:2009, EN61000-3-2:2014 and EN61000-3-3:2013), and **Restriction of the use of certain hazardous substances (Rohs)** 2011/65/EU (standard EN50581:2012).

With the following technical characteristics::

Power	Class	IP	IK	Glow wire test
230V 50Hz	II	44	07	850

Signed and stamped:

 **Normagrup**

**Normagrup Technology, S.A**  
Parque Tecnológico de Asturias  
Parcela 10  
33428 Llanera (Asturias)  
España / Spain  
[normagrup.com](http://normagrup.com)

Normagrup Technology, S.A.  
Parque Tecnológico de Asturias, Parcela 10  
33428 Llanera (Asturias). España / Spain  
T. 985 267 100 / F. 985 266 992  
[normagrup.com](http://normagrup.com)

  
**Mike Jaureguizar**  
General Manager